

## Monthly Update for August 2024

### **Water:**

- Kerr Electric installed water analyzers and sensor.
- Continued to investigate PFAS requirements concerning continual water monitoring.
- Purchased a new trash pump and parts for the old pump.
- Ordered and received a new chlorine field test kit.
- Continued to update on lead and copper revised rule and further requirements concerning notifications to residents.
- Spoke to Ludwig Electric concerning exhaust fan in chlorine room.
- Meeting with Bridget and Gina to discuss lead line service notification letters.
- Reviewed Senate Bill 5 concerning lead service line procedures.
- All IDEM yearly water samples collected and sent to laboratory. This included lead and copper samples.
- Met with WTH and went over mapping system for lead and copper service line updates.
- Spoke to water employees about procedures for meter reading and what to look for when diagnosing meter problems.

### **Wastewater:**

- Scheduled Starweld to repair north digester airline.
- Continued working on permits for manhole rehab on Main Street, sketches, measurements.
- Motor windings burned out on blower motor. Ludwigs ordered a new motor.
- Kerr Electric ordered a new VFD for the blower motor for digester.
- Started documenting repair and maintenance entries for IWORQ software.
- Continued to correspond with INDOT concerning permits for manholes.

- Signed IDEM capacity certificate for upcoming development in the county along Fairfield Causeway Road.
- Signed IDEM capacity certificate for 4-H sewer main.

### **Utility:**

- Spoke with Rob Seig concerning golf course survey status, low hanging limb on Franklin Ave, trees on 3<sup>rd</sup> Street, 4<sup>th</sup> & Mill Street, 5<sup>th</sup> Street,
- Met at golf course to go over irrigation system and need for new pump.
- Ordered 2 ½ inch repair clamps for irrigation system at golf course.
- Spoke to Triad Engineering about getting a new map for golf course irrigation system.
- Spoke to Franklin County Health Department, several times, concerning a complaint received about a roofing company and the material they are using.
- Continued to work with Miami Valley Construction who is installing new gas main.
- Received complaint about Oregon Hill and trees growing in INDOT right-of-way.
- Initiated complaint concerning a storage building being placed without a permit.
- Conference call with attorney concerning house and storm water issues.
- Met with Great Plains representative at pool to look over alarm system and cameras.
- Attended IWORQ training meetings.
- Met with Ben Harrison and Charlie Mason at golf course and went over project at hole # 11.